

INVITATION FOR BIDS (IFB) NO. CCR176251B  
FOR  
5986A & 5986B HALE ULUWEHI  
AGRICULTURE FACILITY AND GREENHOUSE RENOVATION  
WINDWARD COMMUNITY COLLEGE  
HONOLULU, HAWAII  
PROJECT NO. CCR-17-6251B  
ADDENDUM NO. 03  
NOVEMBER 29, 2019

The items listed hereinafter are hereby made a part of the contract for the above project and shall govern the work, taking precedence over previously issued plans and specifications governing the items mentioned:

**A. CHANGES TO SPECIFICATIONS:** The following pages of solicitation documents are revised:

1. Revised Sections: The following previously issued specification sections are revised:
  - a. SECTION 07410 – PREFORMED METAL STANDING SEAM ROOFING.
  - b. SECTION 07411 – PREFORMED METAL SIDING.
2. SECTION 0710 – PREFORMED METAL STANDING SEAM ROOFING.
  - a. Revise paragraph 1.04A as follows:

“A. Installer: The roofing system installer shall be approved and authorized by the metal roofing system manufacturer to install the system, and shall have a minimum 3 years of experience as an approved applicator with that manufacturer. The applicator shall have applied 5 installations of similar size and scope as this project within the previous 3 years.”
  - b. Revise paragraph 1.05B.2 as follows:

“2. Additionally, the metal roofing system components for the project as identified by the Contract Drawings for this project, shall be warranted for a minimum period of 15 years from the project acceptance date. Manufacturer/Supplier shall provide the materials for replacement or repair, any component supplied by them, when installed and maintained according to the manufacturer's instructions, which fail to provide a watertight and waterproof system due to defective materials. All materials required to perform any repair work shall be provided by the manufacturer/supplier.”

3. SECTION 07411 – PREFORMED METAL SIDING

a. Revise paragraph 1.05B.2 as follows:

“2. Additionally, the metal system components for the project as identified by the Contracting Drawings for this project, shall be warranted for a period of 15 years from the projected date. Manufacturer/Supplier shall provide the materials for replacement or repair, any component supplied by them, when installed and maintained according to the manufacturer's instructions, which fail to provide a watertight and waterproof system due to defective materials. All materials required to perform any repair work shall be provided by the manufacturer/supplier.”

**END OF ADDENDUM NO. 3**